



# KERALA WATER AUTHORITY

QUALITY CONTROL SUB DISTRICT LAB

MALAPARAMBA, KOZHIKODE

Ph: 0495 2964751

E-mail : [qualitysdmalaparamba@gmail.com](mailto:qualitysdmalaparamba@gmail.com)

Report No -KWA/KKD/37/25


Date of issue: 08/01/2025

Customer Name & Address	1.Date of Receipt	: 06/01/2025
<b>BHARATHIYA VIDYA BHAVAN SCHOOL C/O PRINCIPAL SUJATHA RAJAGOPAL CHEVAYUR</b>	2. Sample condition	: FIT FOR ANALYSIS
	3.Sampling done by	: PARTY
	4.Sample code	: 37/25
	5.Source of sample	: OPEN WELL
	6.Sample quantity	: 100mL
	7.Test performing dates From : 06/01/2025	To : 08/01/2025

Sl. No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012	Result
1	Coliforms	CFU/100 ml	IS 15185(part1) 2002 reaffirmed2016	Shall not be detectable in any 100ml sample	ABSENT
2	E coli	CFU/100 ml	IS 15185(part1) 2002 reaffirmed2016	Shall not be detectable in any 100ml sample	ABSENT

TNTC- Too Numerous To Count

NB:- The results stated above related only to the samples(S) submitting for testing. This test Certificate shall not be reproduced except in full without the written approval of the Laboratory.



Authorized By : Microbiologist

KWA/KKD/F4

Issue No. 01

Issue Date :01/01/2022

Rev.No. 00

Rev.Date : 00

*[Signature]*  
5/2/2025  
**PRINCIPAL**  
Bharatiya Vidya Bhavan School  
Bhavans' Hill  
Chevayur Calicut-1